



Public Health
Prevent. Promote. Protect.

Gasconade County Health Department

300 Schiller Street, Hermann, MO 65401

(573) 486-3129 FAX (573) 486-3745 County # 073

Food Inspection Report

SITE NO.	INV NO.	IR NO.	DATE	INSPECTION TIME	INSPECTOR
10038	1		12/05/2025	12:00 PM - 12:30 PM	Struttmann, Drew

SITE INFORMATION	INVENTORY/MANAGER/OWNER	SERVICE TYPE/FREQUENCY
RESERVE CELLARS OF HERMANN 2204 HWY 100 HERMANN MO 65041 573-486-3330	70 Tavern/Bar/Winery/Distillery; Wines Pam Schroeder Owner: RESERVE CELLARS OF HERMANN 573-486-3330	Regular Inspection Low Priority

COMMENTS

<u>CODE</u>	<u>DESCRIPTION</u>
-------------	--------------------

998 Temperatures

Hot Water 56F
Drink Cooler Ambient 39F

999 Education Provided OR Comments

No priority violations during this inspection.

Violations: Core - 1

CORE VIOLATIONS SUMMARY

<u>CODE</u>	<u>DESCRIPTION</u>	<u>CORRECTED</u>
8	Adequate handwashing facilities supplied & accessible	_____

CORE VIOLATIONS DETAIL

<u>CODE</u>	<u>DESCRIPTION</u>
-------------	--------------------

8 Risk Factors and Interventions

Observed hot water temperature to be inadequate.

CODE **DESCRIPTION**

5-202.12(A) A handwashing sink shall be equipped to provide water at a temperature of at least one hundred degrees Fahrenheit through a mixing valve or combination faucet.

I HEREBY, ACKNOWLEDGE THE ISSUANCE AND RECEIPT OF THIS OFFICIAL Food Inspection Report.

Drew Struttmann, EPHS Inspector 1881

OWNER / MANAGER SIGNATURE